



Results Report

Order ID: 7022658

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: Little Ferry PS - Memorial Primary School
130 Liberty Street
Little Ferry, NJ 07643

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7022658-01
Collector: DT

Site: LFP-BLANK
Collect Date: 02/12/2017 10:05 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 02/14/17 RPV 02/23/17 20:56 RPV

Sample Number: 7022658-02
Collector: DT

Site: LFP-WC-1FL-HALLA-1
Collect Date: 02/12/2017 10:06 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 02/14/17 RPV 02/23/17 20:58 RPV

Sample Number: 7022658-03
Collector: DT

Site: LFP-WC-1FL-HALLA-2
Collect Date: 02/12/2017 10:07 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 02/14/17 RPV 02/23/17 21:00 RPV

Sample Number: 7022658-04
Collector: DT

Site: LFP-WC-2FL-HALLD
Collect Date: 02/12/2017 10:15 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 02/14/17 RPV 02/23/17 21:02 RPV

Sample Number: 7022658-05
Collector: DT

Site: LFP-WC-1FL-HALLB-1
Collect Date: 02/12/2017 10:17 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 02/14/17 RPV 02/23/17 21:04 RPV

Report Generated On: 02/27/2017 3:55 pm
STL_Results Revision #1.6

7022658
Effective: 07/09/2014





Sample Number: 7022658-06	Site: LFP-WC-1FL-HALLB-2	Sample ID:
Collector: DT	Collect Date: 02/12/2017 10:18 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	02/14/17	RPV	02/23/17 21:06	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7022658-07	Site: LFP-WC-1FL-HALLC-2	Sample ID:
Collector: DT	Collect Date: 02/12/2017 10:19 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	02/14/17	RPV	02/23/17 21:15	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7022658-08	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 02/14/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.0	µg/L	EPA 200.8	1.00	1	02/14/17	RPV	02/23/17 21:21	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7022658-09	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 02/14/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.1	µg/L	EPA 200.8	1.00	1	02/14/17	RPV	02/23/17 21:23	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:


Alana Kopicz
Project Manager

Report Generated On: 02/27/2017 3:55 pm 7022658
STL_Results Revision #1.6 Effective: 07/09/2014





6



7022658
Alana Kopicz

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u>	Phone: _____	e: <u>Little Ferry Public Schools- Lead in Drinking Water</u>
Address: <u>20 Lauck Road</u> <u>Mohnton, PA 19540</u>	Fax: <u>610-856-5040</u>	Address: <u>Memorial Primary School</u> <u>130 Liberty Street, Little Ferry, NJ 07643</u>
Contact Name: <u>Kelly Mays</u>	Email: <u>kmays@karlenv.com</u>	Payment / P.O. Info: <u>16-0900</u>

Comments:

NJ DOE Lead in Drinking Water Samples

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	LFP-BLANK	2/12/2017	1009	DT	Lead	1	PW	G	P	H	Blank pH < 2
	LFP-WC-1FL-HALLA-1	2/12/2017	1006	DT	Lead	1	PW	G	P	H	
	LFP-WC-1FL-HALLA-2	2/12/2017	1007	DT	Lead	1	PW	G	P	H	
	LFP-WC-2FL-HALLD	2/12/2017	1015	DT	Lead	1	PW	G	P	H	
	LFP-WC-1FL-HALLB-1	2/12/2017	1017	DT	Lead	1	PW	G	P	H	
	LFP-WC-1FL-HALLB-2	2/12/2017	1018	DT	Lead	1	PW	G	P	H	
	LFP-WC-1FL-HALLB-3	2/12/2017		DT	Lead	1	PW	G	P	H	DT
	LFP-WC-2FL-HALLC-1	2/12/2017		DT	Lead	1	PW	G	P	H	DT

Relinquished By: <u>Darren Townsend</u>	Date: <u>2-14-17</u>								
	Time: <u>11:10</u>								
Received By: <u>Kelly Mays</u>	Date: <u>2-14-17</u>	Temp °C: _____	<p style="text-align:center;">Sample Conditions</p> Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y <input type="checkbox"/> N						
	Time: <u>11:10</u>	Acceptable: Y / N							
Relinquished By: <u>Kelly Mays</u>	Date: <u>2-14-17</u>	Temp °C: _____							
	Time: <u>1205</u>	Acceptable: Y / N							
Received in Lab By: <u>San D...</u>	Date: <u>2/14/17</u>	Temp °C: <u>12.2</u>	<p style="text-align:center;">Matrix Key</p> NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample						
	Time: <u>12:05</u>	Acceptable: Y / N							
			<p style="text-align:center;">Bottle Type Key</p> P = Plastic G = Glass O = Other				<p style="text-align:center;">Reporting Options</p> <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report		
			<p style="text-align:center;">Sample Type Key</p> G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite				<p style="text-align:center;">SDWA Sample Types</p> D=Distribution E=Entry Point R=Raw C=Chew S=Special M=Maximum Residence		
			<p style="text-align:center;">Preservative Key</p> N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required						

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.

